

**Fire Department Water Tanker Shuttle Accreditation**

Presented To: Champlain Township

**ACCREDITED FIRE STATIONS**

F.S L'Original (6)

F.S Vankleek Hill (6)

Date Test Passed: September 7<sup>th</sup> 2019

Flow Achieved: 626 I.G.P.M. 2,850 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose  
Elaine Rose  
Partner

This Certificate Expires on: September 1<sup>st</sup>, 2024